

STATE UNIVERSITY OF NEW YORK AT ALBANY
Albany, New York 12203

DATE: 2 October, 1967
FROM: Walter M. Tisdale
TO: President Evan R. Collins
SUBJECT: Campus Progress Report No. 103

This morning we inspected and accepted the basement region of the Business Administration building. This takeover omitted the equipment rooms and one storeroom, which is necessary for the electrician to occupy for electrical equipment needed to finish up the punch list. This storeroom, however, will be vacated within a week or two.

We also inspected and accepted the salt water system of the Aquarium. You will remember that a number of changes were requested here, in order to give us greater assurances that the salt water would not be contaminated by metallic ionization. These changes have now all been satisfactorily completed and the system may be put into operation immediately.

Inspected, but not accepted owing to certain incompletions, were the ladies locker room and the post office area on the north-western corner of the podium. These areas however should soon be completed and in our hands for use within a month.

Walter M. Tisdale
Assistant to the President
for Planning & Development

Cc: Vice President Milton Olson
Vice President Earl Drossler
Dr. Robert Allen
Dr. John Carlock
Mr. John F. Buckhoff, Jr.