

STATE UNIVERSITY OF NEW YORK AT ALBANY

Albany, New York 12203

DATE: 6 November, 1967

FROM: Walter M. Tisdale

TO: President Evan R. Collins

SUBJECT: Campus Progress Report No. 109

This morning we inspected and accepted all of the fountains that have been completed in connection with Group I buildings. These were located in the center of the main entrance to the Library and in the north and south courts of the Library, plus the large fountain at the main entrance to the Campus Center. Operating instructions are being given to our personnel. The fountains seem to be in good order and we are now owners and operators of these facilities.

Since some of the night time temperatures are now reaching into the 20's, there may be a limited time in which we may continue to operate before it is necessary to turn off the fountains. The ones at the main entrances of the Campus Center and Library are not so vulnerable, owing to their protected location, but the ones in the north and south courts of the Library have underground piping that is exposed. These will have to be turned off earlier in order to protect the fountains.

Walter M. Tisdale
Assistant to the President
for Planning & Development

Cc: Mr. John F. Buckhoff, Jr.
Mr. H. David VanDyck